



300MM MINIMUM CLEARANCE TO BE PROVIDED FROM THE CLOSEST FITTING OR PIPE TO THE SIDE WALLS OF THE CAGE.  
 100MM MINIMUM CLEARANCE TO BE PROVIDED FROM THE HIGHEST FITTING OR PIPE TO THE LID OF THE CAGE.

| SCHEDULE OF ITEMS |   |
|-------------------|---|
| ITEM NO.          | DESCRIPTION   |
| 1                 | 50mm x 50mm X 4mm GALVANISED STEEL MESH                             |
| 2                 | 30MM x 30MM X 2 MM GALVANISED STEEL TUBE                            |
| 3                 | GALVANISED 10MM X 50MM DYNA BOLTS                                   |
| 4                 | LATCH   |
| 5                 | WELDED HINGE  |
| 6                 | 12MM STEEL PINS   |
| 7                 | WELDED STEEL LUG  |
| 8                 | 4MM GALVANISED CHAIN LINK OR EQUIVALENT TO OPEN CAGE LID BEYOND 90° |
| 9                 | CONCRETE BASE 100mm THICK   |