

Protection of South East Water Supply Assets Other Authority Works

This document outlines the minimum requirements for works within the vicinity of South East Water's potable and recycled water supply assets.

General Conditions

- The design and construction of water supply assets is to be in accordance with the most recent edition of *WSAA Water Supply Code of Australia (MRWA Edition)*.
- No additional loading is to be applied to existing water supply assets.
- Only use products and materials approved by South East Water.

Asset Location

- The location and depth of water mains are to be proven by hand excavation prior to the commencement of works, particularly when boring across or parallel to an existing water main.
- The contractor should make every attempt to locate water meters to ascertain the position of the property service pipes prior to excavation.
- The contractor should provide detailed plans showing major utilities and all South East Water's assets including property connections.
- Although every effort is taken in the preparation of asset information provided, South East Water accepts no responsibility for loss, damage or injury suffered as a result of a discrepancy.
- Any damage resulting from failure to comply with these requirements may result in penalties being imposed as provided for in the current legislation including the *Water Act*. In the event that damage is caused to South East Water's assets please contact Faults & Emergencies on 132 812.

NOTE: South East Water should be contacted if assets cannot be located based upon Dial Before You Dig information. Likewise, when additional assets are located which are not shown on plans and are otherwise thought to be water mains, South East Water should be contacted.

Design Considerations

- The minimum final cover over water mains is 450mm (nature strips and footpaths), 600 mm (sealed roads), 750 mm (major roadways), and 1200 mm (freeways and arterial roads).
- The maximum final cover of any water main is 1.5 times the minimum cover or 1500 mm, whichever smaller.

- Minimum vertical and horizontal clearances are to be in accordance with Table 5.5 Water Main Clearances of *WSAA Water Supply Code of Australia (MRWA Edition)*.
- Where a road or carriageway is widened and would result in the water services lengths exceeding 30 m, a separate water main will need to be laid on the opposite side of the road to service these customers.

Construction

- When constructing new assets or repairing old assets in close proximity to South East Water's water mains, support may be required to stop any unnecessary loading on the water main which may result in the main bursting.
- During construction only 1 pipe joint on the existing water main should be exposed at any time.
- Hand compaction using vibrating plates or pedestrian rollers is required over and within 1 m of the outer edge of water mains and where there is less than 600 mm cover; no vibrating rollers.
- Exposure of water mains during construction works, including boxing out, may require the use of stabilised backfill to protect our asset and is to be approved by South East Water.
- The minimum cover required over water mains during construction (boxing out) is 450 mm.
- Care should be taken when excavating behind a bend, dead end etc., to ensure the thrust restraint is not disturbed.
- No blasting is to be carried out within 10 m of a water main.
- Any damage to pipe coating systems, fittings etc. is to be reported to and repaired by South East Water.
- Surface fittings are to be accessible at all times to allow for emergency shut down of the mains and all surface fittings must be adjusted to suit finished surface levels.
- It should be noted that prior to any works and upon completion of your works South East Water may inspect the area to confirm all of our surface fittings are intact and operable.
- Where a bore is to pass across or parallel within 1 m of the outer edge of an existing main, the position of the main shall be proven by excavation. All or part of this excavation shall be by hand as directed by a South East Water representative. The excavation shall be extended to 1 m from the main on the side from which the bore will approach, and the position and direction of the bore head checked when it reaches this excavation to ensure the required minimum clearance between the bore and the main maintained. In addition, progressive management of the length of the bore shall be made to ensure the bore head has not missed the check excavation and travelled beyond it.

Alterations to South East Water's Assets

Where there is a requirement for adjustment of surface fittings, service re-connections, mains lowering and relocations, this can be arranged by emailing minorwaterworks@sew.com.au.

All alterations to South East Water assets as a result of the proposed works are to be conducted at the project owner's cost.

24/7 Emergency Response 132 812

Revised: September 2018

South East Water Corporation ABN 89 066 902 547
101 Wells Street Frankston VIC 3199
www.southeastwater.com.au